

**TEXAS TECH POLICE DEPARTMENT
SUMMARY OF DAILY REPORTS
El Paso TTUHSC
DATE: October 10, 2006**

TIME	UNIT	REMARKS
		SHIFT 1
1152	223	Officer Gammon investigated an MVA in the rear alley behind the Medical Center. A TTUHSC vehicle driven by a maintenance employee tried to fit between a parked panel van and a temporary chain link fence, causing minor damage to both vehicles and the fence. See Tech Only ST-3, Case # 06-153.

Entry reviewed and approved by Lt. A. Quintela on October 11, 2006 at 1100 hrs.

		SHIFT 2
1730	222	Officer Martinez documented a Fire Alarm in the Medical Center. A contractor ruptured a sewer line in the building; the spillage caused a smoke detector to be rendered inoperable, causing the fire alarm to go off. Necessary repairs were made, and the fire system returned to normal operation at 1841 hrs. See Case Number 06-154.

Entry reviewed and approved by Lt. A. Quintela on October 11, 2006 at 1100 hrs.

SHIFT 3

No entries on this date.

Entry reviewed and approved by Lt. A. Quintela on October 11, 2006 at 1100 hrs.

SIGNED _____