

**TEXAS TECH POLICE DEPARTMENT  
HEALTH SCIENCES CENTER, EL PASO, TEXAS  
SUMMARY OF DAILY REPORTS  
Date: September 26, 2007**

TIME	UNIT	REMARKS
		SHIFT 1
1045	222	Sgt. Martinez documented information regarding a false alarm at the Archer Building. The El Paso Fire Department did not respond. Several wires were cut due to construction in the building warehouse area and this caused a power shortage causing the activation. There were no reported injuries or damages. See incident report # 07-129EP.

---

Entry was reviewed and approved by Lt. T. Quintela on September 27, 2007 at 0800 hours.

SHIFT 2

No entries this date.

---

Entry was reviewed and approved by Lt. T. Quintela on September 27, 2007 at 0800 hours.

SHIFT 3

No entries this date.

---

Entry was reviewed and approved by Lt. T. Quintela on September 27, 2007 at 0800 hours.

SIGNED: \_\_\_\_\_