

**TEXAS TECH POLICE DEPARTMENT
HEALTH SCIENCES CENTER, EL-PASO, TEXAS
SUMMARY OF DAILY REPORTS
Date July 21, 2018**

TIME	UNIT	REMARKS
SHIFT 1		
1235	TTPD	An Officer documented a fire alarm activation which occurred on the second floor of the Clinical Sciences Building (CSB). Dust triggered the smoke detector. El Paso Fire Department (EPFD) did not respond to the scene. See incident report #18-104EP.
Entry written by Sgt. Stoltz on July, 23, 2018 at 0600.		
SHIFT 2		
		No entries this date.
Entry written by Sgt. Stoltz on July, 23, 2018 at 0600.		
SHIFT 3		
		No entries this date.
Entry written by Sgt. Stoltz on July, 23, 2018 at 0600.		

SIGNED: _____