

**TEXAS TECH POLICE DEPARTMENT
HEALTH SCIENCES CENTER, EL PASO, TEXAS
SUMMARY OF DAILY REPORTS
Date: 10-25-17**

TIME	UNIT	REMARKS
------	------	---------

SHIFT 1

No entries this date.

Entry reviewed and approved by Sgt. Stoltz on October 26, 2017 at 0800 hours.

SHIFT 2

1043	TTPD	An Officer documented a fire alarm activation, which occurred, in the basement of the Academic Education Center. A hot water pump motor malfunctioned causing it to overheat and smoke, which activated the alarm.. There were no reported injuries or EPFD response. See incident report # 17-198EP.
------	------	---

Entry reviewed and approved by Sgt. Stoltz on October 26, 2017 at 0800 hours.

SHIFT 3

No entries this date.

Entry reviewed and approved by Sgt. Stoltz on October 26, 2017 at 0800 hours.

SIGNED: _____