TEXAS TECH POLICE DEPARTMENT
HEALTH SCIENCES CENTER, EL-PASO, TEXAS
SUMMARY OF DAILY REPORTS
Date February 27, 2020

TIME	UNIT	REMARKS
SHIFT 1		
1301	TTPD	An Officer documented a fire alarm activation, which occurred on first floor Orthopedic Clinic of the CSB. An Accumulation of dust set off the smoke detector. There were no reported injuries or El Paso Fire Department response. See incident report #20-014EP.
Entry written by Lt. Stoltz on February 28, 2020 at 0600.		
SHIFT 2		
	TTPD	No entries this date.
Entry written by Lt. Stoltz on February 28, 2020 at 0600.		
SHIFT 3		
	TTPD	No entries this date.
Entry written by Lt. Stoltz on February 28, 2020 at 0600.		

SIGNED: _____