TEXAS TECH POLICE DEPARTMENT
HEALTH SCIENCES CENTER, EL PASO, TEXAS
SUMMARY OF DAILY REPORTS
Date: 04-17-18

TIME	UNIT	REMARKS

SHIFT 1

No entries this date.

Entry reviewed and approved by Sgt. Stoltz on April 18, 2018 at 0800 hours.

SHIFT 2

1403	TTPD	An Officer documented a fire alarm activation, which occurred in the Orthopedics Department located on the first floor of the Clinical Science Building. A clogged water pump drain set off a smoke detector. There were no reported injuries. El Paso Fire Department responded to the scene due to the fire alarm activation. See incident report #18-061EP.

Entry reviewed and approved by Sgt. Stoltz on April 18, 2018 at 0800 hours.

SHIFT 3

No entries this date.

Entry reviewed and approved by Sgt. Stoltz on April 18, 2018 at 0800 hours.

SIGNED: _____