

**TEXAS TECH POLICE DEPARTMENT
HEALTH SCIENCES CENTER, EL-PASO, TEXAS
SUMMARY OF DAILY REPORTS
Date March 30, 2020**

TIME	UNIT	REMARKS
SHIFT 1		
	TTPD	No entries this date.
Entry written by Lt. Stoltz on March 31, 2020 at 0600.		
SHIFT 2		
	TTPD	No entries this date.
Entry written by Lt. Stoltz on March 31, 2020 at 0600.		
SHIFT 3		
0023	TTPD	An Officer documented a fire alarm activation, which occurred in the Elevator Mechanical room located on the fifth floor of the Medical Science Building. Smoke from an overheated wall mounted air conditioner triggered the fire alarm system. There were no reported injuries or El Paso Fire Department response. See incident report #20-020EP.
Entry written by Lt. Stoltz on March 31, 2020 at 0600.		

SIGNED: _____