

**TEXAS TECH POLICE DEPARTMENT**  
**SUMMARY OF DAILY REPORTS**  
**Date April 17, 2020, 2020**

TIME	UNIT	REMARKS
SHIFT 1		
0637	TTPD	An officer documented information in reference to a fire alarm, which occurred at the Computer Center. A faulty pipe caused a steam leak, activating the fire suppression sprinklers. See incident report # 200293.
Entry written by Lieutenant R. Mogg on April 17, 2020 at 1400 hours.		
SHIFT 2		
		No entries this date
Entry written by Sergeant C. Bates on April 17, 2020 at 2200 hours.		
SHIFT 3		
		No entries this date.
Entry written by Lieutenant K. Miller on April 18, 2020 at 0600 hours.		

SIGNED: \_\_\_\_\_